

# IGLU INUIT MONO WT SCHEME

|                                                                         |
|-------------------------------------------------------------------------|
| 1. Freeze Protection (Choose One):                                      |
| A) Antifreeze valves (for both outdoor pipes)                           |
| B) 25%- 35% glycol in the system fluid                                  |
| C) Heated cables (for both outdoor pipes)                               |
| 2. Air relief valves should be used at the highest point of the system. |

