

MAX CASCADE SCHEME

1. Freeze Protection: 25%- 35% glycol in the system fluid.
2. Air relief valves should be used at the highest point of the system.
3. 2-core, 0.75 mm² shielded cable should be used for the communication line between the cascade units.

